



Certificate of Conformity

Certificate: 14600-4S

Master Contract: LC 1225106

Project: 14600

Date Issued: April 15, 2019

Issued to: Fire by Design
3255 Pepper Lane Suite 103
Las Vegas, Nevada
USA 89120

Certification System Type 3
(ISO / IEC 17067)

The products listed below are eligible to bear the LabTest Certification Mark with adjacent indicators 'C' and 'US', and the subject area as shown below.



Issued by:

Certification Manager

PRODUCTS

- Component: Power Supply
- Model Nos:
 - PS-30V185
 - PS-30V320
- Ratings:
 - PS-30V185 – 30V, 6.6A, 200W Max
 - PS-30V320 – 30V, 10.7A, 320W Max

APPLICABLE REQUIREMENTS & SUBJECT AREA

- UL 379: 2013
- CSA C22.2 No. 89-15

CONDITIONS OF ACCEPTABILITY

- For outdoor use only
- For use in ambient temperature -40°C to +90°C

The 'C' and 'US' indicators adjacent to the LabTest Certification Mark shall signify that the product has been evaluated by an accredited laboratory to the applicable Standards respectively. The subject area shall be displayed with the LabTest Certification Mark to identify the Standard Number, and Revision Level.